



County of San Diego
Department of Planning and Land Use
BUILDING DIVISION

ACCESSIBILITY CORRECTION LIST

Public Accommodations
& Commercial Buildings

14B⁷

**Storage, Warehouse, Factory, and
High-Hazard Occupancies/Uses**

PLAN CHECK NUMBER:

OWNER:

GENERAL REQUIREMENTS

1. Specific occupancy-related accessibility provisions may modify general requirements but never at the exclusion of them.
CBC 1103B.1
2. Regardless of classification per CBC Chapter 3, these accessibility provisions apply to any portion of a facility with storage, warehouse, factory, or high-hazard use.
CBC 1103B.1

STORAGE FACILITIES

3. Identify at least one accessible storage unit on an accessible route for each type of storage unit available.
CBC 1125B.1
4. Dimension clear and level floor space minimum 30 inches by 48 inches allowing forward or parallel approach to each accessible storage unit.
CBC 1125B.2
5. Specify door hardware for accessible storage units complying with the following:
 - ☐ Within reach ranges of CBC Figure 11B-5C(a) or CBC Figure 11B-5D(a) and (b)
 - ☐ Operable with maximum 5 pounds of force
 - ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist*CBC 1125B.3 and CBC 1125B.4*
6. Any office areas shall comply with accessibility correction list 14B².
CBC 1107B.2(2)

WAREHOUSES

7. Provide accessible route to and throughout warehouse areas on floor nearest grade and other floors accessible via level entry, pedestrian ramp, or elevator.
CBC 1107B.2(1)
8. Any office areas shall comply with accessibility correction list 14B².
CBC 1107B.2(2)
9. Any sanitary facilities serving warehouse and office areas shall comply with accessibility correction lists 9B and 10B.
CBC 1107B.2(3)

FACTORIES

10. Provide accessible route to and throughout major or principal factory floor areas.
CBC 1107B.1(1)
11. Any office areas shall comply with accessibility correction list 14B².
CBC 1107B.1(2)
12. Any sanitary facilities serving warehouse and office areas shall comply with accessibility correction lists 9B and 10B.
CBC 1107B.1(3)

HIGH-HAZARD FACILITIES


13. CBC Chapter 11B accessibility provisions apply to the following areas in high-hazard facilities:
 - ☐ Spaces used by public as customers, clients, or visitors
 - ☐ Possible places of employment*CBC 1108B.6*

ADDITIONAL REQUIREMENTS


**THIS DOCUMENT IS FOR PLAN REVIEW ONLY.
CORRECTION LIST ITEMS MAY NOT BE REPRODUCED OR COPIED ON PLANS.
PROVIDE COMPLETE DETAILS, DIMENSIONS, AND NOTES TO SATISFY CORRECTION ITEMS.**

5201 RUFFIN ROAD, SUITE B, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553


[HTTP://WWW.SDCPLU.ORG](http://www.sdcplu.org)



CBC FIGURE 11B-5C(a) – REACH RANGES (FORWARD APPROACH)



(a) CLEAR FLOOR SPACE PARALLEL APPROACH



(b) HIGH AND LOW SIDE REACH LIMITS

CBC FIGURE 11B-5D – REACH RANGES (PARALLEL APPROACH)

THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT
OF THE *CALIFORNIA BUILDING CODE*, THE CODE TEXT SHALL GOVERN.